



Northbrook, Illinois • (708) 272-8800
Melville, New York • (516) 271-6200
Santa Clara, California • (408) 985-2400
Research Triangle Park,
North Carolina • (919) 549-1400

CERTIFICATE OF COMPLIANCE

CERTIFICATE NUMBER: 020496 - R9700B

ISSUE DATE: April 2, 1996

Issued to: **Minnesota Mining & Mfg., Co.
3M Center, Building 207-1S-02
ST. Paul, MN 55144, U.S.A.**

Report Reference: **R9700, November 5, 1992**

This is to Certify that
representative samples of: **Elastomeric Fill Void or Cavity Material
designated Type CP-25 WB+ (water base plus)
caulk.**

Have been investigated by Underwriters Laboratories Inc. in accordance with the Standard(s)
indicated on this Certificate.


Standard(s) for Safety: **UL1479, Fire Tests of Through-Penetration
Firestops;
UL2079, Tests for Fire Resistance of Building
Joint Systems.**


Additional Information: **The Type CP-25 WB+ intumescent caulk is intended to be used in various
Through-Penetration Firestop Systems as specified in the UL Fire
Resistance Directory. (For System Nos. Caulk is used in, see Addendum
attached).**

**Only those products bearing the UL Classification Marking should be considered as being
covered by UL's Classification and Follow-Up Service.**

The UL Classification Marking includes: the name "Underwriters Laboratories Inc."; the word "Classified"; a control
number (may be alphanumeric) assigned by UL; a statement to indicate the extent of UL's evaluation of the product;
and, the product category name (product identity) as indicated in the appropriate UL Directory.

LOOK FOR THE UL CLASSIFICATION MARKING ON THE PRODUCT

Engineer: 
Underwriters Laboratories Inc.
Dorothy Trawkowska

Review Engineer: 
Underwriters Laboratories Inc.
Jolanta M. Wroblewska